



City of Rancho Cucamonga
 BUILDING AND SAFETY SERVICES DEPARTMENT
FIRE CONSTRUCTION SERVICES
 10500 Civic Center Dr. | Rancho Cucamonga, CA. 91730
 T: (909) 477-2710 | (F) (909) 477-2711 | www.CityofRC.us



RANCHO CUCAMONGA FIRE DISTRICT FIRE EXTINGUISHER INSTALLATION AND SPACING REQUIREMENTS

Portable fire extinguishers are required during occupancy, construction, alterations or demolition of any building. Additional fire extinguishers may be required by the fire inspector during inspection.

Fire extinguishers shall be tagged by a company licensed by the California State Fire Marshal upon installation. The fire extinguisher must display the current year.

Size and spacing requirements

<u>Hazard</u>	<u>Minimum size</u>	<u>Area</u>	<u>Travel Distance</u>
Light	2A10BC	5,000 Square feet	75 Feet
Ordinary	3A40BC	3,000 Square feet	75 Feet
Extra	4A60BC	4,000 Square feet	50 Feet

Occupancy and uses:

- Light Hazard: Offices, classrooms, churches, assembly rooms, residential
- Ordinary Hazard: Retail storage & display, light manufacturing, warehouses and industrial with minimal combustible storage.
- Extra Hazard: Auto repair, aircraft repair, warehouses and industrial with combustible materials, high piled stock, flammable liquid usage.

The type, spacing and location of fire extinguishers shall be determined in accordance with this policy.